

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:
 District Disaster Response & Fire Officer
 Andhra Pradesh, Tirupati

To:
 The District Educational Officer, Tirupati
 District.,
 The District Educational Officer, Tirupati
 District.

File No: 34771/TPT/DFO/2026, Date: 12/09/2026
Occupancy NOC RC Number: 19459/TPT/DFO/2023

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **BGS VIJNATHAM SCHOOL, represented by Panchamishree infra, SY No: 257-1,257-2,OPP. AIRPORT POLICE STATION, RENIGUNTALA, RENIGUNTALA MANDAL, TIRUPATI DISTRICT.** - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.01-09-2025.
 3. This Office NOC for Occupancy Rc No. 19459/TPT/DFO/2023, Dt.05/08/2023
 4. Renewal NOC For Occupancy 19459/TPT/DFO/2023, Dt.04/08/2026
 5. Online Application for Renewal NOC of Panchamishree infra, SY No: 257-1,257-2,OPP. AIRPORT POLICE STATION, RENIGUNTALA, RENIGUNTALA MANDAL, TIRUPATI DISTRICT. - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 12-09-2026.

-- X --

The Management of BGS VIJNATHAM SCHOOL, represented by Panchamishree infra, SY No: 257-1,257-2,OPP. AIRPORT POLICE STATION, RENIGUNTALA, RENIGUNTALA MANDAL, TIRUPATI DISTRICT. has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.30116/- vide challan No. 10108032082026, Dated 11/09/2026 at ONLINE, ONLINE.

BGM VIJNATHAM SCHOOL

2. The builder has constructed a Non Multi Storeyed Building with Ground Floor + One Upper Floor with a height of 7.8 Mtrs for Educational Occupancy (Category - B1) in a total plot area of 80800.94 sq. meters.

3. Open Spaces:

NOTE: It is the responsibility of the local Municipal authorities i.e., Municipal Corporations, Panchayats, IALA, SEZ, APHC etc., to ensure the setbacks as per local building rules are in force vide G.O.Ms.No.44 Home (Prisons & Fire) Department Dated:12-03-2024.

4. The builder has provided the following means of escape:

Sl	Details of Staircases	Required Nos / Meters as per NBC	Provided Nos / Meters
1	Internal Staircases	Min 1 No. - 1.5 Meters Each	3 Nos. - 2.00 Meters Each

Sl	Details of Staircases	Required Nos / Meters as per NBC	Provided Nos / Meters
2	External Staircases	Min 1 No. - 1.5 Meters Each	2 Nos. - 1.50 Meters Each
	Total	3 Meters	9.00 Meters

5. Occupant Load :

Sl	Floor	Built up area (Sq Mtrs)	Occupancy Type	No of Occupants as declared by the builder	No of Occupants as per NBC	Aggregate width of Staircases Required (Meters)	Aggregate width of Staircases Provided (Meters)
1	Ground Floor	2978.2	Educational	744	744	7.44	9.00
2	First Floor	3045	Educational	761	761	7.61	9.00
	Total	6023.2		1505			

6. The minimum Fire Fighting Installations required and provided as per Table 7 of Part 4 of National Building Code of India 2016 are:

Sl	Fire Fighting Equipment	Provided
1	Fire Extinguishers	61 Nos.
2	Hose Reel Systems	7 Nos.
3	Terrace Tank	10000 Ltrs. Ltrs
4	Booster Pump	01 NO 450 LPM.

- Provide ABC 5 kg/6 kg fire extinguishers

7. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023

8. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate vide reference 4th cited to the existing Non Multi Storeyed Building.

9. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **Panchamishree** infra SY No: **257-1,257-2,OPP. AIRPORT POLICE STATION,RENIGUNTLA,RENIGUNTLA MANDAL,TIRUPATI DISTRICT.**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

10. The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

11. This Periodical Renewal Fire Certificate is valid from 12/09/2026 to 11/09/2027.

12. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire Services Act 1999 and Rules, 2006.

13. Challan Info:

Challan Number	Challan Date	Challan Amount
10108032082026	2026-09-11	30116

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended by the management.

Nil

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"

"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"

"సురక్షిత పాఠశాలలు, సురక్షిత మైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై స్పృహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."



Your Sincerely, ,

[Signature]
12/9/26

District Disaster Response & Fire Officer,
Tirupati District

In case of emergency, please call 101 or 8772260101 or 9963736778

Copy to Management Panchamishree infra,
Copy to Assistant District Fire Officer Concerned
Copy to Station Fire Officer Concerned